

Stormwater Management

410-887-3768
FAX 410-887-4804

April 24, 2015

Subra Das, P.E.
Gannett Fleming
7133 Rutherford Road, Suite 300
Windsor Mill, MD 21244-2718

RE: CATONSVILLE PUMPING STATION SUPPLY MAIN
Stormwater Management Variance
Patapsco Watershed
EPS Project I.D. M150009
EPS Tracking Number: 01-15-1956

Dear Mr. Das:

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. This section of the regulations allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of this article would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the replacement of a water main by cut and cover. The existing cover conditions will be re-established once the 36 inch pipe is installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff as a result of this project.

Please contact Lamar A. Williams of my staff at 410-887-3768 should you have any questions.

Very truly yours,

/signed/

Vincent J. Gardina, Director
Department of Environmental Protection
& Sustainability

VJG:jcm

C: Gerald McHenry – DPW
Jeff Stamm – Gannett Fleming